

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7125-1209:167 Page 1 of 1

CATEGORY: Fire Alarm Devices For The Hearing Impaired

LISTEE: System Sensor, 3825 Ohio Ave., St. Charles IL 60174
Contact: Andrej Nikolic (630) 377-6674

DESIGN: Models MASS1215ADA, MASS121575ADA, MASS2415ADA, MASS2415ADAS, MASS241575ADA, MASS241575ADAS, MASS2475ADA, MASS24110ADA; MAEH1215ADA, MAEH121575ADA, MAEH2415ADA, MAEH2415ADAS, MAEH241575ADA, MAEH241575ADAS, MAEH2475ADA, MAEH24110ADA; PS1215ADA, PS121575ADA, PS2415ADA, PS2475ADA, PS241575ADA, and PS24110ADA horn/strobe devices. Unit may employ suffix "W" indicating white face plate. All units are not intended for field assembly. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical Rating: 10.5 - 17 VDC For MASS12/PS12 Series
20 -30 VDC For MASS24/MAEH24/PS24 Series

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as horn/strobes suitable for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. All units are for wall mount and indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

09-18-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 8, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy**

